

PANEL DISCUSSION:

LEAD AND COPPER IN DRINKING WATER

Sponsored by:
Georgia Section, American Water Works Association

MODERATOR: Peter Frost, Executive Director, Douglasville-Douglas County Water and Sewer Authority and Chair of GAWWA's Water Utility Council, P.O. Box 1157, Douglasville, Georgia 30133.

REFERENCE: *Proceedings of the 1993 Georgia Water Resources Conference*, held April 20 and 21, 1993, at The University of Georgia, Kathryn J. Hatcher, Editor, Institute of Natural Resources, The University of Georgia, Athens, Georgia.

Moderator: Peter Frost, Executive Director, Douglasville-Douglas County Water and Sewer Authority, P.O. Box 1157, Douglasville, Georgia 30133.

Panel Discussions:

Population Exposure to Lead and Copper,

Henry Abadin, Agency for Toxic Substances and Disease Registry, 1600 Clifton Road, Mailstop E29, Atlanta, Georgia 30333.

Government Programs Addressing Lead and Copper in Potable Water Supplies,

Nolton Johnson, Water Resources Management Branch, Georgia Dept. of Natural Resources, Environmental Protection Division, Suite 1266, E. Tower, 205 Butler Street, S.E., Atlanta, Georgia 30303.

Local Implementation of Federal and State Programs,

Michael Patton, Douglasville-Douglas County Water and Sewer Authority.

Relating Water Test Results to the Public,

Susan Waters, Cobb County - Marietta Water Authority, 680 South Cobb, Marietta, Georgia 30060.

LEAD EXPOSURE IN THE GENERAL POPULATION

by Henry Abadin

Health Effects of Lead

Lead has long been recognized as a toxin, affecting virtually every organ and system of the body. One of the most sensitive target organs is the nervous system. Exposures to high concentrations of lead, particularly in children, can cause encephalopathy and death, whereas exposures to lower concentrations are associated with reduced IQ scores, neurobehavioral effects, and impaired

hearing (NAS 1972; Schwartz and Otto, 1987; Bellinger and Needleman, 1983; de la Burde and Choate, 1972, 1975). In addition, lead affects the hematopoietic (Roels and Lauwerys, 1987; Roels et al, 1979) and cardiovascular systems (de Kort, 1987; Coate and Fowles, 1989; Kirkby and Gyntelberg, 1985).

There is evidence that lead also affects the kidneys (Pollock and Ibels, 1986; Huang et al, 1988; Vyskocil et al, 1989), and the immune (Ewers et al, 1982; Hillam and Ozkan, 1986) and reproductive systems (Baghurst et al, 1987; Chowdhury et al, 1984). In fact, spontaneous abortions, sterility, and stillbirths were noted in female lead workers and wives of lead workers as early as the 18th and 19th centuries (ATSDR 1988). Many of the effects noted in humans are supported by data from studies in animals.

Sources of Lead

For the general population, the major route of exposure to lead is ingestion of lead-contaminated water, food, soil, dust, and lead-based paint chips. Soil, dust, and lead-based paint are of particular importance for young children from "pica" (eating of non-food items) and normal hand to mouth activity that results in the ingestion of lead-contaminated dust on the hands.

Although lead is a naturally occurring element that is found in the earth's crust and in all compartments of the biosphere, anthropogenic processes have distributed and concentrated lead in the environment where it has provided a source for human exposure. In 1984, the primary source of lead to the atmosphere was the use of leaded gasoline; however, the phase-down of leaded fuel has reduced the contribution of lead from this source. Despite the phase-down, decades of leaded-gasoline use have resulted in near roadway soil lead levels of 30-2000 $\mu\text{g/g}$ above background levels (10-30 $\mu\text{g/g}$) (EPA 1986; Mielke et al, 1989).

The overall decline of lead use through the termination of old practices (e.g., leaded gasoline, lead-based paint, leaded solder) has reduced the potential of lead exposure to the general population. However, past use remains a

THE LEAD AND COPPER RULE: A UTILITY'S PERSPECTIVE

By Michael W. Patton

significant problem for certain populations. For example, an estimated 57 million private housing units built before 1980 still contain lead-based paint. Of these, 14 million are believed to be in unsound condition (HUD 1990). Flaking paint, paint chips, and weathered powdered paint are major sources of lead exposure for young children residing in these homes (Bornschein, 1986; EPA 1986). Improper removal of lead (by burning, sanding, or scraping) from housing known to contain lead-based paint can significantly increase lead levels in dust, an important exposure pathway for small children.

Lead in drinking water occurs primarily from corrosion of lead-containing materials used in the distribution system. The concentration of lead in water depends on the corrosiveness of the water, age and lead content of the materials, and contact time of the water with the lead-containing materials. In 1986, the Safe Drinking Water Act Amendments banned the use of lead solder or flux containing more than 0.2% lead (EPA 1988, 1989b). Because of the wide use of lead solder to connect copper pipes, most public water systems still supply buildings containing lead soldered joints and fixtures. The combination of corrosive water and lead pipes or lead-soldered joints can create localized zones of high lead concentrations that exceed 500 $\mu\text{g/L}$ (EPA 1989a).

The reduction in the use of lead solder in food cans has minimized this as a source of lead exposure for the general population. In 1991, approximately 3.8% of domestic food cans were made with lead solder (Bolger, 1991). Although the number of lead-soldered domestic cans will continue to decline, imported food cans may still contain lead solder.

Other sources of lead exposure include using "non-Western" folk remedies, drinking or eating from lead-crystal decanters and glasses or lead-glazed ceramic-ware, and various hobbies such as making stained glass, using some types of artist's paint, and using firing ranges.

Implementation of the new Lead and Copper Rule published by EPA on June 7, 1991 presents numerous challenges for public water systems. The rule, designed to minimize consumers' exposure to lead and copper in drinking water, establishes an action level for both lead and copper at the customer's water tap. Based upon sampling among high risk homes in the community, the rule requires water systems to take additional action to reduce lead and/or copper levels, including educating the public, if the action levels are exceeded.

Concerns to be addressed by water systems include the selection of sampling sites, completion of public education requirements if action levels are exceeded, and performance of corrosion control studies. Additionally, all of these should be accomplished without diminishing consumer confidence in the water produced by the water system. Ultimately, compliance with this rule requires water systems to develop a plan that results in a carefully coordinated effort involving system employees, customers, the regulatory agency, and the news media.

REFERENCES

- ATSDR. 1988. The nature and extent of lead poisoning in children in the United States: A report to Congress. Atlanta, GA: U.S. Department of Health and Human Services, Public Health Service, Agency for Toxic Substances and Disease Registry.
- Baghurst PA, Robertson EF, McMichael AJ, et al. 1987. The Port Pirie cohort study: Lead effects on pregnancy outcome and early childhood development. *Neurotoxicology* 8:395-401.
- Bellinger DC, Needleman HL. 1983. Lead and the relationship between maternal and child intelligence. *J Pediatr* 102:523-527.
- Bolger PM, Carrington CD, Capar SG, et al. 1991. Reductions in dietary lead exposure in the United

- States. Chemical Speciation and Bioavailability 3(31-4):31-36.
- Bornschein RL, Succop PA, Krafft KM, et al. 1986. Exterior surface dust lead, interior house dust lead and childhood lead exposure in an urban environment. In: Hemphill DD, ed. Trace substances in environmental health, v. 20. University of Missouri 322-332.
- Chowdhury AR, Dewan A, Ghandhi DN. 1984. Toxic effect of lead on the testes of rat. *Biomed Biochim Acta* 43:95-100.
- Coate D, Fowles R. 1989. Is there statistical evidence for a blood lead-blood pressure relationship? *Journal of Economics* 8:173-184.
- de Kort WLAM, Verschoor MA, Wibowo AAE, et al. 1987. Occupational exposure to lead and blood pressure. A study of 105 workers. *Am J Ind Med* 11:145-156.
- de la Burde B, Choate MS Jr. 1972. Does asymptomatic lead exposure in children have latent sequelae? *J Pediatr* 81:1088-1091.
- de la Burde B, Choate MS Jr. 1975. Early asymptomatic lead exposure and development at school age. *J Pediatr* 87:638-642.
- EPA. 1986. Air quality criteria for lead. Research Triangle Park, NC: U.S. Environmental Protection Agency, Office of Research and Development, Office of Health and Environmental Assessment, Environmental Criteria and Assessment Office. EPA 600/8-83-028F.
- EPA. 1988. Reportable quantities for releases of lead, methyl isocyanate: Delisting of ammonium thiosulfate. U.S. Environmental Protection Agency. Federal Register 53:6762-6768.
- EPA. 1989a. National primary drinking water regulations. U.S. Environmental Protection Agency. Code of Federal Regulations. 40 CFR 141, 142.
- EPA. 1989b. Supplement to the 1986 EPA air quality criteria for lead. Vol. 1. Addendum. Research Triangle Park, NC: U.S. Environmental Protection Agency, Office of Health and Environmental Assessment. EPA/600/8-89/049A, ECAO-R-0297, NTIS PB89-181374.
- Ewers U, Stiller-Winkler R, Idel H. 1982. Serum immunoglobulin, complement C3, and salivary IgA level in lead workers. *Environ Res* 29:351-357.
- Hillam RP, Ozkan AN. 1986. Comparison of local and systemic immunity after intratracheal, intraperitoneal, and intravenous immunization of mice exposed to either aerosolized or ingested lead. *Environ Res* 39:265-277.
- Huang JX, He FS, Wu YG, et al. 1988. Observations on renal function in workers exposed to lead. *Sci Total Environ* 71:535-537.
- HUD. 1990. Lead-based paint: Interim guidelines. Department of Housing and Urban Development. Federal Register 55:14556-14789.
- Kirkby H, Gyntelberg F. 1985. Blood pressure and other cardiovascular risk factors of long-term exposure to lead. *Scand J Work Environ Health* 11:15-19.
- Mielke HW, Adams JL, Reagan PL, et al. 1989. Soil-dust lead and childhood lead exposure as a function of city size and community traffic flow: The case for lead abatement in Minnesota. *Environ Chem Health* 9(Supp):253-271.
- NAS. 1972. Lead: Airborne lead in perspective: Biologic effects of atmospheric pollutants. Washington, DC: National Academy of Sciences, 71-177, 281-313.
- Pollock CA, Ibels LS. 1986. Lead intoxication in paint removal workers on the Sidney Harbour Bridge. *Medical Journal of Australia* 145:635-639.
- Roels HA, Lauwerys R. 1987. Evaluation of dose-effect and dose-response relationships for lead exposure in different Belgian population groups (fetus, child, adult men and women). *Trace Elem Med* 4:80-87.
- Roels HA, Balis-Jacques MN, Buchet J-P, et al. 1979. The influence of sex and of chelation therapy on erythrocyte protoporphyrin and urinary δ -aminolevulinic acid in lead-exposed workers. *J Occup Med* 21:527-539.
- Schwartz J, Otto DA. 1987. Blood lead, hearing thresholds, and neurobehavioral development in children and youth. *Arch Environ Health* 42:153-160.
- Vyskocil A, Pancl J, Tusl M, et al. 1989. Dose-related proximal tubular dysfunction in male rats chronically exposed to lead. *J Appl Toxicol* 9:395-400.